

R403.5.17 Climatic design conditions.

A. HVAC equipment shall be sized according to the ACCA Manual S or an equivalent method, based on the building's heating and cooling load calculations by using ASHRAE Handbook of Fundamentals or the ACCA Manual J. Oversizing of heating equipment shall not exceed 40 percent of the calculated load requirements and oversizing of cooling equipment shall not exceed 15 percent of the calculated load requirements.

B. Design conditions shall be determined according to Table 403.5.17. Design condition adjustments may be determined by the building official if local climates differ from the tabulated temperatures based on local climate data.

TABLE R403.5.17 CLIMATIC DATA DESIGN CONDITIONS

CITY	SUMMER Db/Wb °F	WINTER Db °F
Aitkin	82/72	-24
Albert Lea	85/72	-15
Alexandria	86/70	-21
Bemidji	84/68	-24
Cloquet	82/68	-20
Crookston	84/70	-27
Duluth	81/67	-20
Ely	82/68	-29
Eveleth	82/68	-26
Faribault	86/73	-16
Fergus Falls	86/71	-21
Grand Rapids	81/67	-23
Hibbing	82/68	-19
International Falls	83/67	-28
Litchfield	85/71	-18
Little Falls	86/71	-20
Mankato	86/72	-15
Minneapolis/St. Paul	88/72	-15
Montevideo	86/72	-17
Mora	84/70	-21
Morris	84/72	-21
New Ulm	87/73	-15
Owatonna	86/73	-16
Pequot Lakes	84/68	-23
Pipestone	85/73	-15
Redwood Falls	89/73	-17
Rochester	85/72	-17
Roseau	82/70	-29
St. Cloud	86/71	-20
Thief River Falls	82/68	-25
Tofte	75/61	-14
Warroad	83/67	-29
Wheaton	84/71	-20
Willmar	85/71	-20
Winona	88/74	-13
Worthington	84/71	-14

For SI: °C = [(°F)-32]/1.8.

Db = dry bulb temperature, degrees Fahrenheit

Wb = wet bulb temperature, degrees Fahrenheit